

Technical data



Cable ties **22** in **U60X**

Description

- For tying of cables and conduits for indoor use. ⁽¹⁾
- Hand thread, easier mounting at site.
- High tensile strength.
- UL approval for finished product.
- Inside teeth.
- Own raw material. Insulating halogen free material.
- RoHS-Compliant.
- Colour: Grey RAL 7035.

Quality Marks ⁽²⁾



EN 62275:2009
Licencia nº: 030/001929



EN 62275:2009
Licencia nº: 670605



EN 62275:2009
Licencia nº:40011920



File E 75725 (M)



GOST R 50827:2009
Part 1 to 5
licence n°: POCC. ES.
AI75.H02240

Approvals ⁽²⁾



Certificat d'Approbation de
type nº 2535D/04934/G0/BV



Type approval certificate
TAE0000115

Technical data

Cable ties **22** in **U60X**

Characteristics

EN 62275:2009

Component	Non metallic.
Minimum installation temperature	-30°C
Service temperature	-40°C a +85°C
Contribution to fire	Non-flame propagation.
Resistance to UVs	Not Declared.
Resistance to traction (minimum tensile strength)	<ul style="list-style-type: none"> ▪ 13,6 Kg for cable ties of 3,6 mm. ▪ 22,6 Kg for cable ties of 4,8 mm. ▪ Type 1: cable ties of 3,6 mm and 4,8mm .
Max./Min. application diameter	<ul style="list-style-type: none"> ▪ 2233-3: 32mm / 1,6mm ▪ 2244-3: 45mm / 1,6mm ▪ 2247-3: 76mm / 1,6mm

MS 3367

Dimensions ⁽³⁾	<ul style="list-style-type: none"> ▪ 2233-3: MS 3367-5 ▪ 2244-3: MS 3367-1 ▪ 2247-3: MS 3367-7
---------------------------	---

Compulsory regulations

2014/35/CE EUROPEAN DIRECTIVE

CE Marking	Conformity with standard EN 62275:2009.
------------	---

Characteristics of U60X raw material

- Base raw material: Polyamide 6.6 (natural colour and grey RAL 7035 colour)
- Silicone contents: silicone free
- Phtalate contents acc./ASTM D2124-99:2004: phtalate free
- Halogen contents acc./EN 50267-2-1: <0,5% ⁽⁴⁾
- UL flammability tests on plastic materials according to ANSI/UL 94: 1990: Degree UL94 V2
- L.O.I. Oxygen index according to EN ISO 4589:1999: ≥29
- UL Approval: File E41938 EM
- Classification acc./ASTM D6779:2003: PA 0111

Technical data

Cable ties **22** in **U60X**

Notes

1. Due to the variety of factors affecting the performance of the cable ties under chemical agents (concentration, temperature, Uvs, mounting way, etc),the particular atmosphere of certain installations must be individually studied with a specific test.
2. Except for new part numbers, which are under process of obtaining quality marks and approvals.
www.unex.net/QM.pdf
3. Cable ties without MS designation fulfill the conditions set in the standards for items with the same width, except for the length.
4. Detection limit for the analytical technique applied.

* It is recommended to keep the bag closed until use.

** All information contained herein is completely objective and is the result of a wide experience in satisfying our costumers` requirements . For more details, please visit our website.

*** Unex aparellaje eléctrico, S.L. reserve the right to modify any characteristics of the products manufactured. This document is an uncontrolled copy and will not be updated if its content changes.

28/6/2016